



Technical Report No.: 64.181.24.00375.01 Rev.00

Date: 2024-03-20

Client: Name: EcoFlow Inc.

> Address: RM 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road,

> > Zhancheng Community, Fuhai Street, Bao'an District, Shenzhen City, Guangdong Province, P.R.China

Contact person: Molly Li

Manufacturer: EcoFlow Inc. Name:

> Address: RM 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road,

> > Zhancheng Community, Fuhai Street, Bao'an District, Shenzhen City, Guangdong Province, P.R.China

Factory: Name: Guangdong New Energy Technology Co., Ltd

> Address: NO.125, Chuangyou Road, Xintang Town, Zengcheng,

> > 511340 Guangzhou, Guangdong, PEOPLE'S REPUBLIC OF

CHINA

Test object: Product: AIR TO WATER HEAT PUMP

> Model: EF AD-P1-9K0-S1

Trade mark:

Test specification: 1 EN 14825:2022

> EN 14511-3:2022 4 1 EN 12102-1:2022

Purpose of

examination:

Test according to the test specification

1 (EU) No 813/2013

1 EU 2016/2282:2016-11-30

The test results show that the presented product is in compliance with the above Test result:

listed test specifications.

Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question. It does not imply a general statement regarding the quality of products from regular production. For further details please see testing and certification regulation, chapter A-3.4.

Project No: 64.181.24.00375.01

Rev.: 00

Date: 2024-03-20 Page: 1 of 18

www.tuvsud.com

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China





1 Description of the test object

1.1 Function

Manufacturer's specification for intended use:

The appliance is air to water heat pump.

Manufacturer's specification for predictive use:

According to user manual

Sound power level dB(A):

Series No:

| | 3 | | | | | | | | |
|-----|-------------------------------|-------------------|--------------------------------------|--------|--|--|--|--|--|
| 1.2 | Consideration of the fores | eeable | use | | | | | | |
| | ☐ Not applicable | | | | | | | | |
| | ☑ Covered through the appli | ed stanc | ard | | | | | | |
| | ☐ Covered by the following of | commen | | | | | | | |
| | ☐ Covered by attached risk a | analysis | | | | | | | |
| 1.3 | Technical Data | | | | | | | | |
| | Model: | EF / | D-P1-9K0-S1 | | | | | | |
| | Rated Voltage (V): | 220- | 220-240V~ | | | | | | |
| | Rated Frequency (Hz): | 50 | 50 | | | | | | |
| | Rated Power (W): | see | | | | | | | |
| | Rated Current (A): | see the nameplate | | | | | | | |
| | Protection Class: | Class I | | | | | | | |
| | Protection Against Moisture : | IP X | | | | | | | |
| | Construction: | Stat | onary | | | | | | |
| | Supply connection : | | Non detachable cord | | | | | | |
| | | V | Permanent connection to fixed wiring | | | | | | |
| | Operation mode: | V | Continuous operation; | | | | | | |
| | | | Intermittent operation; | | | | | | |
| | | | Short time operation; | | | | | | |
| | Refrigerant/charge (kg): | F | 290 / 0.78kg | | | | | | |
| | Declared parameters : | 7 | Average □ Warmer □ | Colder | | | | | |

N/A

212301020164030030010

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 2 of 18



 $\mbox{T\"{U}V}$ $\mbox{S\"{U}D}$ Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China Tel: +86 20 38320668





2 Order

2.1 Date of Purchase Order, Customer's Reference

Date of Purchase Order: 2024-01-15, 2024-03-20

Customer's Reference: EcoFlow Inc.

2.2 Test Sample(s)

• Reception date(s): 2024-01-15

Location(s) of reception:

For Energy test:

Guangzhou Customs District Technology Center

(CNAS accredited laboratory with Registration No.CNAS L2322)

Address: No.3, Desheng East Road, Daliang, Shunde District, Foshan, Guangdong, China

For Noise tests:

CVC Testing Technology Co., Ltd.

(CNAS accredited laboratory with Registration No.CNAS L0095)

Address: No.3, Tiantai Yilu, Kaitai Avenue, Science City, Guangzhou, Guangdong, China

• Condition of test sample(s): completed and can be normal operation

2.3 Date(s) of Testing

2024-01-15 to 2024-03-04

2.4 Location(s) of Testing

Same as 2.2

2.5 Points of Non-compliance or Exceptions of the Test Procedure

N/A

3 Test Results

| ☑ Decision rule according to ILAC-G8:09/2019 clause 4.2.1 Binary statement for simple |
|--|
| acceptance rule or IEC Guide 115:2023, clause 4.3 Simple acceptance was applied. |
| ☐ Decision rule according to customer's requirements was applied. It is: |
| \square Decision rule according to ILAC-G8:09/2019 clause 4.2.2 Binary statement with guard band - guard band length = 95 % extended measurement uncertainty, was applied. |
| ☐ Decision rule (based on ILAC-G8:09/2019 clause 4.2.3 Non-binary statement with guard band |
| guard band length = 95 % extended measurement uncertainty) for an upper specification limit (A lower limit or specification with an up-per and a lower limit is treated similarly.): |
| •Compliance with the requirement: If a specification limit is not breached by a measurement |
| result plus the expanded uncertainty with a 95% coverage probability, then compliance with the |
| specification will be stated (e. g. Pass). |
| •Non-compliance with the requirement: If a specification limit is exceeded by the measurement result minus the expanded uncertainty with a 95% coverage probability, then non-compliance with the specification will be stated (e. g. Fail). |
| •Inconclusive result: If a measurement result plus/minus the expanded uncertainty with a 95 % |
| coverage probability overlaps the limit it will be stated that it is not possible to state compliance o |
| non-compliance. |
| ☐ There are no statements to conformity or no results with measurand stated in this report, no |
| decision rule has been applied |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 3 of 18 www.tuvsud.com



3.1 Positive Test Results

See Appendix I

4 Remarks

4.1 General

The user manual has been examined according to the minimum requirements described in the product standard. The manufacturer is responsible for the accuracy of further par-ticulars as well as of the composition and layout.

4.2 When the product is placed on the market, it must be accompanied with safety Instructions written in official language of the country. The instructions shall give information re-garding safe operation, installation and maintenance.

5 Documentation

• Appendix I: Test results

Appendix II: Marking plate

Appendix III: photo documentation

• Appendix IV: Construction data form

• Appendix V: Test equipment list

6 Test History

- The appliance is Air to Water Heat Pump Unit, including a whole compression type refrigerant circuit to heat water in another circuit. The appliance was for cooling and heating water function, this report only for heating capacity test.
- 2) The main power is supplied by a 3-pole supply cord connecting to fixed wiring.
- 3) Water enthalpy method was adopted in this report.
- 4) Standby mode power, off mode power and thermostat-off mode power were tested according to clause 12 of standard EN 14825:2022.
- 5) This test report 64.181.24.00375.01 Rev.00, dated 2024-03-20 bases on original test report 64.181.24.00341.01 Rev.00, dated 2024-03-07 to include the following changes and/or additions, which were considered technical modifications:
 - a) Changing report holder name and address, manufacturer name and address, trademark, model name and appearance,.
 - b) After evaluating, no additional test was needed.

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch TÜV SÜD Group

Tested by: William Liang, Project Handler

printed name, function & signature

Approved by: Plum Li, Designated Reviewer

printed name, function & signature

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 4 of 18 www.tuvsud.com





| Table 1. | Heating mode (Low temperature application): | | | | | | | | ı | P |
|--|---|--------------------|------------------|----------------|---------------|----|---------------------|-------------|----------------------------|------------------------|
| Model | EF AD-P1-9K | 0-S1 | | | | | | | | |
| Product type | Air to Water | Heating season | 7 | Average | | Wa | armer | | Colder | |
| 1. Test condi | ions: | | | | | | | | | |
| Condition | F | Part Load Ra | itio | | he | | door chang | er | Indoor heat exchanger | |
| Condition | Form | nula | Average climates | | | • | (wet) b ature (° | | | let water ures (°C) |
| А | (-7-16)/(Tde | esignh-16) | | 88 | | -7 | (-8) | | a / | 34 |
| В | (+2-16)/ (Td | esignh-16) | | 54 | | 2 | (1) | | a / | 30 |
| С | (+7-16)/(Td | esignh-16) | | 35 | | 7 | (6) | | a / | 27 |
| D | (+12-16)/(To | lesignh-16) | | 15 | | 12 | (11) | | a / 24 | |
| Е | (TOL | 16)/ (Tdesig | nh-16 | 5) | TOL | | | | a / 35.3 | |
| F | (Tbival | signh- | 16) | Tbiv | | | a / 34 | | | |
| G | (-15-16)/(Td | esignh-16) | | N/A | | - | 15 | | N/A | |
| Remark: a) With conditions, the o | capacity is 5.17 | 74kW, the po | wer is | | | | | | en in EN1451 | 1-2 at 30/35 |
| 2.Tested data | | | | 0.04400 | | | | 2410.1 | 1 4/40/ | I . / =\ h. / o . |
| General test conditions/ Part-Load | Unit | A(-7)/W34 (88%) | | 2/W30 (54%) | A7/W2 (35% | | | /W24 5%) | A(-10)/ W35.3 (100%) | A(-7)/W34 (88%) |
| | | Α | | В | С | | | D | Е | F |
| Data collection period | hh: min:sec | 1:10:00 | 1 | :10:00 | 1:10:0 | 00 | 1:1 | 0:00 | 1:10:00 | 1:10:00 |
| The heat pump defrosts | | No | | No | No | | ١ | No | No | No |
| Electrical Prop | erties | | | | | | | | | |
| Voltage | V | 231.7 | 2 | 231.3 | 231.4 | 4 | 23 | 1.4 | 232.0 | 231.7 |
| Current input of the unit | А | 8.08 | | 3.42 | 2.03 | 3 | 1. | 71 | 10.11 | 8.08 |
| Power input of the unit | kW | 1.847 | (| 0.760 | 0.43 | 3 | 0.3 | 363 | 2.166 | 1.847 |
| Compressor | Hz | 81 | | 37 | 23 | | 2 | 23 | 90 | 81 |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 5 of 18

www.tuvsud.com





| Test condition | s User Side | | | | | | | | |
|--|-------------|--------|--------|--------|--------|--------|--------|--|--|
| Water flow | m³/h | 0.88 | 0.88 | 0.88 | 0.88 | 0.88 | 0.88 | | |
| Inlet Water temperature | °C | 28.57 | 26.58 | 24.88 | 23.04 | 29.48 | 28.57 | | |
| Outlet Water temperature | °C | 34.01 | 29.96 | 27.30 | 25.77 | 35.29 | 34.01 | | |
| Test conditions Source Side | | | | | | | | | |
| Barometric pressure | kPa | 101.02 | 101.01 | 101.01 | 101.02 | 101.01 | 101.02 | | |
| Air inlet temperature, DB | °C | -6.93 | 2.14 | 7.06 | 12.02 | -9.95 | -6.93 | | |
| Air inlet temperature, WB | °C | -7.93 | 1.03 | 6.06 | 11.06 | -10.97 | -7.93 | | |
| Summary of th | e results | | | | | | | | |
| Total heating capacity | kW | 5.560 | 3.446 | 2.452 | 2.778 | 5.919 | 5.560 | | |
| Effective power input | kW | 1.827 | 0.740 | 0.413 | 0.343 | 2.147 | 1.827 | | |
| Coefficient of performance (COP) | kW/kW | 3.04 | 4.66 | 5.93 | 8.11 | 2.76 | 3.04 | | |

| Electric power consumptions | Unit | Value |
|--|------|-------|
| Thermostat-off mode [P _{TO}] | kW | 0.012 |
| Standby mode [P _{SB}] | kW | 0.011 |
| Crankcase heater [P _{CK}] | kW | 0.042 |
| Off mode [P _{OFF}] | kW | 0.011 |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 6 of 18 $\underline{www.tuvsud.com}$





| | | | | 1 | | | | | |
|--|-----------|-------------------|-----------------|------|------|---------------------|--|--|--|
| Tdesignh(°C): | -10 | | Tbiv(°C): | -7 | | | | | |
| Pdesignh(kW): | 6.286 | | TOL(°C): | -10 | | | | | |
| Test result A, B, C, D, E, F conditions: | | | | | | | | | |
| Condition | Part load | Measured capacity | Measured COP | Cdh | CR | COP at part load | | | |
| Е | 6.286 | 5.919 | 2.76 | 0.90 | 1.00 | 2.76 | | | |
| F | 5.560 | 5.560 | 3.04 | 0.90 | 1.00 | 3.04 | | | |
| А | 5.560 | 5.560 | 3.04 | 0.90 | 1.00 | 3.04 | | | |
| В | 3.385 | 3.446 | 4.66 | 0.90 | 0.98 | 4.66 | | | |
| С | 2.176 | 2.452 | 5.93 | 0.90 | 0.89 | 5.86 | | | |
| D | 0.967 | 2.778 | 8.11 | 0.90 | 0.35 | 6.83 | | | |

| Conclusions: | Unit | Value |
|--|----------|-------|
| SCOPon: | kWh/kWh | 4.70 |
| SCOP: | kWh/kWh | 4.68 |
| Q _H : | kWh/year | 12986 |
| Q _{HE} : | kWh/year | 2772 |
| $\eta_{s,h}$ | % | 184.4 |
| Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2) | 1 | A+++ |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 7 of 18 www.tuvsud.com







| | 1 | | | | | | | | | | |
|-----------------------------------|--|-----------------------------|--------|------------------|--|----|---------------|------|--------------------------------------|--------------------|--|
| Table 2. | Heating mode (Medium temperature application | | | | | : | | | ı | • | |
| Model | EF AD-P1-9K | (0-S1 | | | | | | | | | |
| Product type | Air to Water | Air to Water Heating season | | | □ Warmer □ | | | | Colder | | |
| 1. Test condit | ions: | | | | | | | | | | |
| Condition | Ī | Part Load Ra in % | itio | | hea | | door chang | er | Indoor heat exchanger | | |
| Condition | Form | nula | | verage imates | Inlet dry (wet) bulb temperature (°C) | | | | Inlet/outlet water temperatures (°C) | | |
| Α | (-7-16)/(Tdesignh-16) | | | 88 | | -7 | (-8) | | a / | 52 | |
| В | (+2-16)/ (To | lesignh-16) | | 54 | | 2 | (1) | | a / | 42 | |
| С | (+7-16)/(Td | esignh-16) | | 35 | | 7 | (6) | | a / | 36 | |
| D | (+12-16)/(To | designh-16) | | 15 | | 12 | (11) | | a / 30 | | |
| Е | (TOI | 16)/ (Tdesig | nh-16 | 5) | TOL | | | | a / 55.3 | | |
| F | (Tbiva | signh- | 16) | Tbiv | | | a / 52 | | | | |
| G | (-15-16)/(To | lesignh-16) | | N/A | | - | 15 | | N/A | | |
| Remark: a) With conditions, the c | capacity is 5.16 | 63kW, the po | wer is | | | | | | en in EN1451 | 1-2 at 47/55 | |
| 2.Tested data General test | Unit | A(-7)/W52 | | 2/W42 | A7/W3 | 26 | A 1 2 | W30 | A (10) / | A / 7\/\/EQ | |
| conditions/ Part-Load | Offit | (88%) | | 54%) | (35% | | | 5%) | A(-10)/ W55.3 (100%) | A(-7)/W52 (88%) | |
| | | А | | В | С | | I |) | Е | F | |
| Data collection period | hh: min:sec | 1:10:00 | 1: | :10:00 | 1:10:0 | 00 | 1:10 | 0:00 | 1:10:00 | 1:10:00 | |
| The heat pump defrosts | · · I NO | | | No | No | | Ν | lo | No | No | |
| Electrical Prop | erties | - | | | | | | | | | |
| Voltage | V | 232.1 | 2 | 231.0 | 231.3 | 3 | 23 | 1.0 | 232.0 | 232.1 | |
| Current input of the unit | А | 9.53 | | 3.89 | 2.29 | | 1. | 99 | 11.81 | 9.53 | |
| Power input of the unit | kW | 2.186 | (| 0.909 | 0.522 | 2 | 0.4 | 134 | 2.683 | 2.186 | |
| Compressor | Hz | 82 | | 37 | 23 | | 2 | :3 | 90 | 82 | |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 8 of 18 $\underline{www.tuvsud.com}$

TÜV®

 $\mbox{T\"{UV}}$ $\mbox{S\"{UD}}$ Certification and Testing (China) Co., Ltd. Guangzhou Branch



Appendix I Test results

| h | 0.55 43.80 51.96 | 0.55 36.94 | 0.55 32.78 | 0.55 | 0.55 | 0.55 | | | |
|-----------|-----------------------------|--|---|---|---|--|--|--|--|
| 9:1 | | 36.94 | 32.78 | 00.40 | | | | | |
| 0:1 | 51.96 | | | 28.49 | 46.30 | 43.80 | | | |
| 0: 1 | | 41.99 | 36.32 | 32.74 | 55.04 | 51.96 | | | |
| urce Side | Test conditions Source Side | | | | | | | | |
| ı | 99.85 | 99.85 | 99.85 | 99.80 | 99.75 | 99.85 | | | |
| | -6.94 | 2.02 | 7.04 | 12.05 | -9.96 | -6.94 | | | |
| | -7.95 | 1.01 | 6.06 | 11.05 | -10.94 | -7.95 | | | |
| sults | | | | | | | | | |
| | 5.219 | 3.214 | 2.273 | 2.687 | 5.593 | 5.219 | | | |
| | 2.180 | 0.904 | 0.516 | 0.429 | 2.677 | 2.180 | | | |
| /kW | 2.39 | 3.56 | 4.40 | 6.26 | 2.09 | 2.39 | | | |
| _ | sults | -6.94 -7.95 sults 5.219 2.180 | -6.94 2.02 -7.95 1.01 sults 5.219 3.214 2.180 0.904 | -6.94 2.02 7.04 -7.95 1.01 6.06 sults 5.219 3.214 2.273 2.180 0.904 0.516 | -6.94 2.02 7.04 12.05 -7.95 1.01 6.06 11.05 sults 5.219 3.214 2.273 2.687 2.180 0.904 0.516 0.429 | -6.94 2.02 7.04 12.05 -9.96 -7.95 1.01 6.06 11.05 -10.94 sults 5.219 3.214 2.273 2.687 5.593 2.180 0.904 0.516 0.429 2.677 | | | |

| Electric power consumptions | Unit | Value | |
|--|------|-------|--|
| Thermostat-off mode [P _{TO}] | kW | 0.012 | |
| Standby mode [P _{SB}] | kW | 0.011 | |
| Crankcase heater [P _{CK}] | kW | 0.042 | |
| Off mode [P _{OFF}] | kW | 0.011 | |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 9 of 18 $\underline{www.tuvsud.com}$



| 3.Calculation/conclusion for SCOP: | | | | | | | | | |
|--|------------------------------------|-------------------|-----------------|------|------|---------------------|--|--|--|
| Tdesignh(°C): | -10 | | Tbiv(°C): | -7 | | | | | |
| Pdesignh(kW): | 5.899 | | TOL(°C): | -10 | | | | | |
| Test result A, B, C, D, E, F conditions: | | | | | | | | | |
| Condition | Part load | Measured capacity | Measured COP | Cdh | CR | COP at part load | | | |
| E | 5.899 | 5.593 | 2.09 | 0.90 | 1.00 | 2.09 | | | |
| F | 5.219 | 5.219 | 2.39 | 0.90 | 1.00 | 2.39 | | | |
| А | 5.219 | 5.219 | 2.39 | 0.90 | 1.00 | 2.39 | | | |
| В | 3.177 | 3.214 | 3.56 | 0.90 | 0.99 | 3.56 | | | |
| С | 2.042 | 2.273 | 4.40 | 0.90 | 0.90 | 4.35 | | | |
| D | 0.908 | 2.687 | 6.26 | 0.90 | 0.34 | 5.24 | | | |
| CR: part load di | CR: part load divided by capacity; | | | | | | | | |

| Conclusions: | Unit | Value |
|--|----------|-------|
| SCOPon: | kWh/kWh | 3.59 |
| SCOP: | kWh/kWh | 3.58 |
| Q _H : | kWh/year | 12188 |
| Q _{HE} : | kWh/year | 3406 |
| $\eta_{s,h}$ | % | 140.1 |
| Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1) | | A++ |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 10 of 18 $\underline{www.tuvsud.com}$



Appendix I Test results

| Table 3a. | Sound power level | Р | | | |
|---|---|---------------------------------|----------------------------------|--------------------|--|
| Model | EF AD-P1-9K0-S1 | | | | |
| | Product type : | | | Air to Water | |
| | Outdoor heat exchanger, Air temperature DB/WB (°C): | | | | |
| Indoor heat exchanger, Water inlet/outlet temperature (°C): | | | | 30.0 / 35.0 | |
| | Voltage (V): | | 230 | | |
| Frequency (Hz): | | | | 50 | |
| | Working condition class : | | | Class A | |
| | Acoustical environment : Windshield type : | | | Hemi-anechoic room | |
| | | | | Sponge | |
| | Measured position amount : | | | 14 | |
| Measured quantity | | L _{WA,indoors} (dB(A)) | L _{WA,outdoors} (dB(A)) | Remark | |
| Sound pressure level `L _{p(ST)} **** | | | 44 | | |
| Measureme | ent distance d * | | 1.0m | | |
| Sound pow | er level L _{wA} **** | | 59 | | |

Setting of controls: according to user manual.

Duct connection:--

Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer

Doc No.: ITC-TTW0902.02E - Rev.13

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 11 of 18





Appendix I Test results

| Table 3b. | Sound power level | Р | | | |
|---|---|---------------------------------|----------------------------------|--------------------|--|
| Model | EF AD-P1-9K0-S1 | | | | |
| | Product type : | Air to Water | | | |
| | Outdoor heat exchanger, Air temperature DB/WB (°C): | | | | |
| | Indoor heat exchang | er, Water inlet/outlet te | emperature (°C): | 47.0 / 55.0 | |
| | Voltage (V): | | | 230 | |
| Frequency (Hz): | | | | 50 | |
| | Working condition class : | | | Class A | |
| | Acoustical environment : | | | Hemi-anechoic room | |
| | Windshield type : | | | Sponge | |
| | Measured position amount : | | | 14 | |
| Mea | sured quantity | L _{WA,indoors} (dB(A)) | L _{WA,outdoors} (dB(A)) | Remark | |
| Sound pressure level `L _{p(ST)} **** | | | 43 | | |
| Measureme | ent distance d * | | 1.0m | | |
| Sound pow | er level L _{wA} **** | | 57 | | |

Setting of controls: according to user manual.

Duct connection:--

Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer

Doc No.: ITC-TTW0902.02E - Rev.13

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 12 of 18









Appendix II Marking plate

Nameplate Model: EF AD-P1-9K0-S1 **EcoFlow PowerHeat Air-to-water Heat Pump** Model/Modell EF AD-P1-9K0-S1 Made in China Power Supply/Spannungsversorgung $220-240V_{\sim} / 50Hz$ EC REP support.eu@ecoflow.com Heating Capacity₁ (kW)/Heizleistung₁ (kW) 3.50-8.81 EcoFlow Europe s.r.o. Doubravice 110, 533 53 Pardubice, Czech Republic Input Power₁ (kW)/Eingangsleistung₁ (kW) 0.58-1.89 support.eu@ecoflow.com Cooling Capacity₂ (kW)/Kühlleistung₂ (kW) 1.53-5.96 EcoFlow Innovation UK Limited Input Power₂ (kW)/Eingangsleistung₂ (kW) 0.33-2.11 41 Devonshire Street Ground Floor Office 1London United Kingdom Rated Input Power (kW)/Nenneingangsleistung (kW) 4 Manufacturer: EcoFlow Inc. RM 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road, Zhancheng Rated Running Current (A)/Nennbetriebsstrom (A) 18.3 Community, Fuhai Street, Bao'an District, Shenzhen City, Guangdong Rated Water Flow (m³/h)/Nenn-Wasserdurchflussrate (m³/h) Province, P.R. China Hotline Number/Hotline Nummer: -DE: 0800 0002566 R290 / 0.78 Refrigerant Type/Filling Weight (kg) / Kältemitteltyp/Füllgewicht (kg) -AT: 0800 018 036 Net Weight (kg)/Nettgewicht (kg) -UK: 0808 8126 006 Net Dimensions (L x W x H) (mm)/Abmessungen (L x B x M) (mm) 1263 x 440 x 875 Water Proof Class/IP-Schutzklasse IPX4 Protection Class against Electric Shock/Schutzklasse gegen elektrischen Schlag 3.0 / 0.9 Max./Min. Refrigerant Pressure (MPa) / Max./Min. Kältemitteldruck (MPa) Storage Refrigerant Pressure Range (Mpa)/Druckbereich des Kältemittels bei der Lagerung (Mpa) 3.5 [Space Heating] Ambient Temp. (DB / WB):7°C / 6°C; 1. [Raumheizung] Umgebungstemp. (DB / WB):7°C / 6°C; Address Addres Water Temp. (Inlet / Outlet):30°C / 35°C Wassertemp. (Eintritt / Austritt):30°C / 35°C 2. [Space Cooling] Ambient Temp. (DB / WB):35°C / -; 2. [Raumkühlung] Umgebungstemp. (DB / WB):35°C / -; Water Temp.(Inlet / Outlet):12°C / 7°C Wassertemp. (Eintritt / Austritt):12°C / 7°C

Project No: 64.181.24.00375.01

Rev.: 00

Date: 2024-03-20 Page: 13 of 18







Appendix III photo documentation

| Details of: | Overall view | | |
|---|--------------|--|--|
| View: General Front Rear Right Left Top Bottom | ■COFLOW | | |

| View: General Front Rear Right Left Top Bottom | HIGHLY WHP07600PSDPC9KQ == 143.5V RoHS 900-7200r/min (at 3300 r/min) 2022.08.10a R290 W5WN5H066UXD 上海海立电器有限公司 SHANGHAI MIGHLY ELECTRICAL A | PPLIANCES OC. LTD. | |
|---|--|--------------------|--|
|---|--|--------------------|--|

Project No: 64.181.24.00375.01

Rev.: 00

Date: 2024-03-20 Page: 14 of 18

www.tuvsud.com



TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



Appendix III photo documentation

| | Fan Motor |
|---|--|
| View: General Front Rear Right Left Top Bottom | BRUSHLESS DC MOTOR (无嗣直流电动机) ROHS ROHS ROHS ROHS ROHS ROHS ROHS ROHS |

| Details of: | Main Control Board |
|---|--------------------|
| View: General Front Rear Right Left Dop Bottom | |

Project No: 64.181.24.00375.01

Rev.: 00

Date: 2024-03-20 Page: 15 of 18 www.tuvsud.com



 $\mbox{T\"{U}V}$ $\mbox{S\"{U}D}$ Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



Appendix III photo documentation

| 230V AC 50Hz Max |
|---|
| Class H TF 95 P1(W) 140 66 IP44 EEI≤0.21-Part 3 I(A) 1.09 0.08 P1(W) MPa 1.0 MPa 1.0 MO:220516,0003 |
| I II III A P |
| I+II : BL1 |
| I+A : BL3 |
| |
| |
| |
| |
| |

Project No: 64.181.24.00375.01

Rev.: 00

Date: 2024-03-20 Page: 16 of 18 www.tuvsud.com



 $\mbox{T\"{U}V}$ $\mbox{S\"{U}D}$ Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China





Appendix IV Construction data form

| Model: <u>EF AD-P1-9K0-S1</u> | | | | |
|-------------------------------|-----------------|--|--|--|
| Part | | Technical data | | |
| 1. Compressor | | | | |
| | Manufacture: | Shanghai Highly Electrical Appliances Co., Ltd | | |
| | Type: | WHP07600PSDPC9KQ | | |
| | Rated capacity: | 1480W | | |
| | Serial-number: | W5WN5H066UXD | | |
| | Specification: | DC143.5V; R290 | | |
| 2. Condenser | | | | |
| | Manufacture: | Jiangsu Yuan Zhuo Equipment Manufacturing Co., Ltd | | |
| | Type: | HZL42A-34AD | | |
| | Heat exchanger: | Plate heat exchanger | | |
| | Dimension(mm): | 333mm×122mm×64mm | | |
| 3. Evaporator | | | | |
| | Manufacture: | Guangzhou Aotai Refrigeration Equipment Co., Ltd. | | |
| | Type: | EF AD-P1-9K0-S1-SD | | |
| | Heat exchanger: | Fin heat exchanger | | |
| | Dimension(mm): | 25mm×21.65mm×1.5mm×1.5 | | |
| 4. Fan motor | | | | |
| | Manufacture: | Zhuhai Kaibang Motor Manufacturing Co., Ltd. | | |
| | Type: | ZWS150-H62 | | |
| | Fan type: | 3 blade | | |
| | Specification: | DC310V; 150W | | |
| 5. Main control board | | | | |
| | Manufacture: | Guangzhou Punp Electronic Co., Ltd. | | |
| | Type: | K.LK050085A.01 | | |
| | Specification: | 220-240V~/50Hz | | |
| 6. Water pump | | | | |
| | Manufacture: | Hefei Xinhu Canned Motor Pump Co., Ltd. | | |
| | Type: | GPA25-11H | | |
| | Specification: | 230VAC; 50Hz; 140W | | |

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 17 of 18 $\underline{www.tuvsud.com}$





Appendix V Equipment List

| No. | Туре | Manufacture | Model | Equipment ID | Calibration Due Date |
|-----|--|-----------------|---------------|--------------|-------------------------|
| 1 | Heat pump energy efficiency testing system | PINXIN | 10HP | 2017J00001 | 2024-11-24 |
| 2 | Electromagnetic flowmeter | KROHNE | OPTIFLUX4100C | H17221264 | 2024-12-21 |
| 3 | Anechoic rooms (hemi-anechoic rooms) | Guangzhou Kinte | - | NC-036-2 | 2028-10-06 |
| 4 | AC source Supply | YANGHONG | YF-3600 | VGDS-0637 | 2024-11-07 |
| 5 | 6 channel data logger | _ | PXI-1033 | VGDY-0257 | 2024-05-17 |
| 6 | PULSE system | B & K | 3660C | VGDY-0184 | 2024-03-15 |
| 7 | Calibrator | B & K | 4231 | HJ-000095 | 2024-07-06 |
| 8 | Long steel tape | _ | 5m | HJ-000150 | 2024-09-11 |
| 9 | Temperature measurement system | _ | _ | NC-036-1 | 2024-06-04 |
| 10 | Atmospheric pressure meter | _ | _ | HJ-000165 | 2024-11-21 |
| 11 | Constant temperature water system | B & K | _ | VGDS-0448 | 2024-04-13 |
| 12 | Windscreen | B & K | WS002-5 | _ | _ |

-- End of Report --

Project No: 64.181.24.00375.01

Rev.: 00 Date: 2024-03-20 Page: 18 of 18 www.tuvsud.com