



### Technical Report No.: 64.181.24.00376.01 Rev.00

Date: 2024-03-20

Client: Name: EcoFlow Inc.

Address: RM 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road,

Zhancheng Community, Fuhai Street, Bao'an District, Shenzhen City, Guangdong Province, P.R.China

Contact person: Molly Li

Manufacturer: Name: EcoFlow Inc.

Address: RM 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road,

Zhancheng Community, Fuhai Street, Bao'an District, Shenzhen City, Guangdong Province, P.R.China

Factory: Name: Guangdong New Energy Technology Development Co., Ltd.

Address: NO.125, Chuangyou Road, Xintang Town, Zengcheng,

511340 Guangzhou, Guangdong, PEOPLE'S REPUBLIC OF

**CHINA** 

Test object: Product: AIR TO WATER HEAT PUMP

Model: EF AD-P3-20K-S1

Trade mark:

Test specification: ☑ EN 14825:2022

☑ EN 14511-3:2022☑ EN 12102-1:2022

☑ EN 14511-4:2022 Clause 4

Purpose of Test according to the test specification

examination:

☑ (EU) No 813/2013

☑ EU 2016/2282:2016-11-30

Test result: The test results show that the presented product is in compliance with the above

listed test specifications.

Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question. It does not imply a general statement regarding the quality of products from regular production. For further details please see testing and certification regulation, chapter A-3.4.

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 1 of 19 www.tuvsud.com

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China







## 1 Description of the test object

## 1.1 Function

Manufacturer's specification for intended use:

The appliance is air to water heat pump.

Manufacturer's specification for predictive use:

According to user manual

	The second secon									
1.2	Consideration of the fore	seeable	use							
	☐ Not applicable									
	Covered through the applied standard     Covered through the applied standard									
	☐ Covered by the following	comment	t							
	☐ Covered by attached risk	analysis								
1.3	Technical Data									
	Model:	EF AD-P3-20K-S1								
	Rated Voltage (V):	380-	-415V, 3N~							
	Rated Frequency (Hz):	50								
	Rated Power (W):	6800	)							
	Rated Current (A):	11.6	;							
	Protection Class:	Clas	s I							
	Protection Against Moisture :	IP X	4							
	Construction:	Stat	ionary							
	Supply connection :		Non detach	able co	ord					
		<b>~</b>	Permanent	conne	ction to fixed	wiring				
	Operation mode:	<b>V</b>	Continuous	operat	ion;					
			Intermittent	operat	ion;					
			Short time of	peration	on;					
	Refrigerant/charge (kg):	F	R290 / 1.65kg							
	Declared parameters :	<b>~</b>	Average		Warmer		Colder			
	Sound power level dB(A):	N/A								

Project No: 64.181.24.00376.01

Series No:

Rev.: 00 Date: 2024-03-20 Page: 2 of 19 www.tuvsud.com

212301040074030050006

Guangzhou Branch

TÜV SÜD Certification and Testing (China) Co., Ltd.



#### 2 Order

#### **Date of Purchase Order, Customer's Reference** 2.1

Date of Purchase Order: 2022-12-07, 2023-06-02, 2024-03-20

Customer's Reference: EcoFlow Inc.

#### Test Sample(s) 2.2

2023-02-10, 2023-06-02 • Reception date(s):

• Location(s) of reception:

For Energy test:

Guangzhou Customs District Technology Center

Address: No.3, Desheng East Road, Daliang, Shunde District, Foshan, Guangdong, China

For Noise tests:

CVC Testing Technology Co., Ltd.

Address: No.3, Tiantai Yilu, Kaitai Avenue, Science City, Guangzhou, Guangdong, China

completed and can be normal operation • Condition of test sample(s):

#### 2.3 Date(s) of Testing

2023-02-10 to 2023-03-20, 2023-06-02 to 2023-06-12

#### Location(s) of Testing 2.4

Same as 2.2

#### 2.5 Points of Non-compliance or Exceptions of the Test Procedure

N/A

#### **Test Results**

☑ Decision rule according to ILAC-G8:09/2019 clause 4.2.1 Binary statement for simple
acceptance rule or IEC Guide 115:2023, clause 4.3 Simple acceptance was applied.
☐ Decision rule according to customer's requirements was applied. It is:
$\square$ Decision rule according to ILAC-G8:09/2019 clause 4.2.2 Binary statement with guard band - guard band length = 95 % extended measurement uncertainty, was applied.
$\square$ Decision rule (based on ILAC-G8:09/2019 clause 4.2.3 Non-binary statement with guard band,
guard band length = 95 % extended measurement uncertainty) for an upper specification limit (A
lower limit or specification with an up-per and a lower limit is treated similarly.):
•Compliance with the requirement: If a specification limit is not breached by a measurement
result plus the expanded uncertainty with a 95% coverage probability, then compliance with the specification will be stated (e. g. Pass).
•Non-compliance with the requirement: If a specification limit is exceeded by the measurement
result minus the expanded uncertainty with a 95% coverage probability, then non-compliance
with the specification will be stated (e. g. Fail).
•Inconclusive result: If a measurement result plus/minus the expanded uncertainty with a 95 %
coverage probability overlaps the limit it will be stated that it is not possible to state compliance or

☐ There are no statements to conformity or no results with measurand stated in this report, no decision rule has been applied.

Project No: 64.181.24.00376.01

non-compliance.

Rev.: 00 Date: 2024-03-20 Page: 3 of 19

www.tuvsud.com

### **Technical Report**



#### **Positive Test Results** 3.1

See Appendix I

#### Remarks

#### 4.1 General

The user manual has been examined according to the minimum requirements described in the product standard. The manufacturer is responsible for the accuracy of further par-ticulars as well as of the composition and layout.

4.2 When the product is placed on the market, it must be accompanied with safety Instructions written in official language of the country. The instructions shall give information re-garding safe operation, installation and maintenance.

#### 5 **Documentation**

- Appendix I: Test results
- Appendix II: Marking plate
- Appendix III: photo documentation
- · Appendix IV: Construction data form
- Appendix V: Test equipment list

#### **Test History** 6

- The appliance is Air to Water Heat Pump Unit, including a whole compression type refrigerant 1) circuit to heat water in another circuit. The appliance was for cooling and heating water function, this report only for heating capacity test.
- The main power is supplied by a 5-pole supply cord connecting to fixed wiring. 2)
- 3) Water enthalpy method was adopted in this report.
- 4) Standby mode power, off mode power and thermostat-off mode power were tested according to clause 12 of standard EN 14825:2022.
- 5) This test report 64.181.24.00376.01 Rev.00, dated 2024-03-20 bases on original test report 64.181.22.04501.02 Rev.00, dated 2023-07-05 to include the following changes and/or additions, which were considered technical modifications:
  - a) Changing report holder name and address, manufacturer name and address, trademark, model name and appearance.
  - b) After evaluating, no additional test was needed.

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch **TÜV SÜD Group** 

Tested by: William Liang, Project Handler

printed name, function & signature

Approved by: Plum Li, Designated Reviewer

printed name, function & signature

Project No: 64.181.24.00376.01

Rev.: 00

Date: 2024-03-20 Page: 4 of 19

www.tuvsud.com

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China





Table 1.	Heating mode (Low temperature application):								F	•
Model	EF AD-P3-20	K-S1								
Product type	Air to Water	Heating season	V	Average		Wa	ırmer		Colder	
1. Test condit	tions:									
Condition	F	Part Load Ra	itio		hea		door chang	er		r heat anger
Condition	Form	nula		verage imates		-	(wet) b ture (°0			let water ures (°C)
Α	(-7-16)/(Tde	esignh-16)		88		-7(	(-8)		a /	34
В	(+2-16)/ (Td	esignh-16)		54		2(	(1)		a /	30
С	(+7-16)/(Td	esignh-16)		35		7(	(6)		a /	27
D	(+12-16)/(To	lesignh-16)		15		12(	(11)		a /	24
Е	(TOL	16)/ (Tdesig	gnh-16	6)		T	OL		a/:	35.3
F	(Tbival	ent-16)/(Tde	signh-	signh-16) Tbiv				a / 34		
G	(-15-16)/(Td			N/A	-15			N/A		
Remark: a) With conditions, the conditions.	capacity is 19.1	20kW, the p	ower i						en in EN 145 i	1-2 at 30/35
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A	2/W30 (54%)	A7/W2 (35%			/W24 5%)	A(-10)/ W35.3 (100%)	A(-7)/W34 (88%)
		А		В	С		[	)	Е	F
Data collection period	hh: min:sec	1:10:00	1	:10:00	1:10:0	00	1:10	0:00	1:10:00	1:10:00
The heat pump defrosts	No			No	No		N	lo	No	No
Electrical Prop	erties					-				
Voltage	V	400.6	;	399.9	399.8	3	39	7.9	400.4	400.6
Current input of the unit	А	6.75		2.99	1.59		1.	17	7.92	6.75
Power input of the unit	kW	4.446		1.900	0.982	2	0.6	697	5.189	4.446
Compressor frequency	Hz	80		36	24		2	:0	90	80

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 5 of 19

www.tuvsud.com



S User Side						
m³/h	3.33	3.33	3.33	3.33	3.33	3.33
°C	30.63	27.96	25.67	23.40	31.86	30.63
°C	34.00	30.06	27.20	24.90	35.35	34.00
Source Side						
kPa	101.02	101.01	101.01	101.02	101.01	101.02
°C	-7.00	2.01	7.01	12.00	-10.00	-7.00
°C	-8.00	0.87	6.01	11.00	-11.00	-8.00
e results						
kW	12.986	8.100	5.896	5.773	13.505	12.986
kW	4.392	1.846	0.929	0.643	5.136	4.392
kW/kW	2.96	4.39	6.35	8.97	2.63	2.96
	m³/h °C °C s Source Side kPa °C °C e results kW	m³/h 3.33 °C 30.63 °C 34.00 Source Side kPa 101.02 °C -7.00 °C -8.00 e results kW 12.986 kW 4.392	m³/h       3.33       3.33         °C       30.63       27.96         °C       34.00       30.06         Source Side         kPa       101.02       101.01         °C       -7.00       2.01         °C       -8.00       0.87         e results         kW       12.986       8.100         kW       4.392       1.846	m³/h       3.33       3.33       3.33         °C       30.63       27.96       25.67         °C       34.00       30.06       27.20         Source Side         kPa       101.02       101.01       101.01         °C       -7.00       2.01       7.01         °C       -8.00       0.87       6.01         e results         kW       12.986       8.100       5.896         kW       4.392       1.846       0.929	m³/h       3.33       3.33       3.33       3.33         °C       30.63       27.96       25.67       23.40         °C       34.00       30.06       27.20       24.90         Source Side         kPa       101.02       101.01       101.01       101.02         °C       -7.00       2.01       7.01       12.00         °C       -8.00       0.87       6.01       11.00         e results         kW       12.986       8.100       5.896       5.773         kW       4.392       1.846       0.929       0.643	m³/h       3.33       3.33       3.33       3.33       3.33         °C       30.63       27.96       25.67       23.40       31.86         °C       34.00       30.06       27.20       24.90       35.35         S Source Side         kPa       101.02       101.01       101.01       101.02       101.01         °C       -7.00       2.01       7.01       12.00       -10.00         °C       -8.00       0.87       6.01       11.00       -11.00         e results         kW       12.986       8.100       5.896       5.773       13.505         kW       4.392       1.846       0.929       0.643       5.136

Electric power consumptions	Unit	Value
Thermostat-off mode [P <sub>TO</sub> ]	kW	0.017
Standby mode [P <sub>SB</sub> ]	kW	0.014
Crankcase heater [P <sub>CK</sub> ]	kW	0.039
Off mode [P <sub>OFF</sub> ]	kW	0.014

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 6 of 19  $\underline{www.tuvsud.com}$ 





3.Calculation/conclusion for SCOP:										
Tdesignh(°C):	-10		Tbiv(°C):	-7						
Pdesignh(kW):	14.680		TOL(°C):	-10						
Test result A, B, C, D, E, F conditions:										
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load				
E	14.680	13.505	2.63	0.90	1.00	2.63				
F	12.986	12.986	2.96	0.90	1.00	2.96				
А	12.986	12.986	2.96	0.90	1.00	2.96				
В	7.904	8.100	4.39	0.90	0.98	4.39				
С	5.081	5.896	6.35	0.90	0.86	6.25				
D	2.258	5.773	8.97	0.90	0.39	7.76				
CR: part load di	CR: part load divided by capacity;									

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	4.64
SCOP:	kWh/kWh	4.63
Q <sub>H</sub> :	kWh/year	30328
Q <sub>HE</sub> :	kWh/year	6548
$\eta_{s,h}$	%	182.3
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)		A+++

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 7 of 19  $\underline{www.tuvsud.com}$ 





Table 2.	Heating mode (Medium temperature application):								F	•	
Model	EF AD-P3-20K-S1										
Product type	Air to Water	Heating season	V	Average		Wa	armer		Colder		
1. Test condit	tions:										
Condition	F	Part Load Ra	itio		hea		door chang	er		r heat anger	
Condition	Form	nula		verage imates		-	(wet) b ature (°0			let water ures (°C)	
А	(-7-16)/(Tde	esignh-16)		88		-7	(-8)		a /	52	
В	(+2-16)/ (Td	esignh-16)		54		2	(1)		a /	42	
С	(+7-16)/(Tde	esignh-16)		35		7	(6)		a /	36	
D	(+12-16)/(To	lesignh-16)		15		12	(11)		a /	30	
Е	(TOL	16)/ (Tdesig	gnh-16	6)		Т	OL		a / 55.3		
F	(Tbival	ent-16)/(Tde	signh-	signh-16) Tbiv					a / 52		
G	(-15-16)/(Td			N/A	-15			N/A			
Remark: a) With conditions, the conditions.	capacity is 18.3	309kW, the p	ower i						en in Eivi45 i	1-2 at 47/55	
General test	Unit	A(-7)/W52	•	2/W42	A7/W3	26	A 1 2	W30	A(-10)/	A(-7)/W52	
conditions/ Part-Load	Offit	(88%)		(54%)	(35%			5%)	W55.3 (100%)	(88%)	
		А		В	С		I	)	Е	F	
Data collection period	hh: min:sec	1:10:00	1	:10:00	1:10:0	00	1:10	0:00	1:10:00	1:10:00	
The heat pump defrosts		No		No	No		N	lo	No	No	
Electrical Prop	erties										
Voltage	V	400.7		400.9	399.8	3	39	7.8	400.8	400.7	
Current input of the unit	А	8.81		3.59	1.90		1.	35	10.76	8.81	
Power input of the unit	kW	5.714	2	2.344	1.238	3	0.8	326	6.847	5.714	
Compressor frequency	Hz	80		38	24		2	20	90	80	

Project No: 64.181.24.00376.01

Rev.: 00

Date: 2024-03-20 Page: 8 of 19

www.tuvsud.com

 $\mbox{T\"{UV}}$   $\mbox{S\"{UD}}$  Certification and Testing (China) Co., Ltd. Guangzhou Branch



Test condition	s User Side						
Water flow	m³/h	1.97	1.97	1.97	1.97	1.97	1.97
Inlet Water temperature	°C	46.64	38.62	33.89	29.05	49.31	46.64
Outlet Water temperature	°C	52.03	42.01	36.35	31.52	55.00	52.03
Test condition	s Source Side	ı					
Barometric pressure	kPa	99.85	99.85	99.85	99.80	99.75	99.85
Air <b>inlet</b> temperature, DB	°C	-7.00	2.00	7.01	12.00	-10.00	-7.00
Air <b>inlet</b> temperature, WB	°C	-8.00	1.06	6.00	11.00	-11.00	-8.00
Summary of th	e results						
Total heating capacity	kW	12.330	7.742	5.591	5.619	13.000	12.330
Effective power input	kW	5.680	2.310	1.203	0.792	6.812	5.680
Coefficient of performance (COP)	kW/kW	2.17	3.35	4.65	7.10	1.91	2.17

Electric power consumptions	Unit	Value
Thermostat-off mode [P <sub>TO</sub> ]	kW	0.017
Standby mode [P <sub>SB</sub> ]	kW	0.014
Crankcase heater [P <sub>CK</sub> ]	kW	0.039
Off mode [P <sub>OFF</sub> ]	kW	0.014

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 9 of 19  $\underline{www.tuvsud.com}$ 





3.Calculation				1						
Tdesignh(°C):	-10		Tbiv(°C):	-7						
Pdesignh(kW):	13.938		TOL(°C):	-10						
Test result A, B, C, D, E, F conditions:										
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load				
E	13.938	13.000	1.91	0.90	1.00	1.91				
F	12.330	12.330	2.17	0.90	1.00	2.17				
Α	12.330	12.330	2.17	0.90	1.00	2.17				
В	7.505	7.742	3.35	0.90	0.97	3.35				
С	4.825	5.591	4.65	0.90	0.86	4.57				
D	2.144	5.619	7.10	0.90	0.38	6.11				

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	3.49
SCOP:	kWh/kWh	3.49
Q <sub>H</sub> :	kWh/year	28796
Q <sub>HE</sub> :	kWh/year	8254
$\eta_{s,h}$	%	136.5
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)		A++

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 10 of 19  $\underline{www.tuvsud.com}$ 



Table 3a.	Sound power level	Р			
Model	EF AD-P3-20K-S1				
	Product type :				
	Outdoor heat exchanger, Air temperature DB/WB (°C):				
	Indoor heat exchang	er, Water inlet/outlet te	emperature (°C):	30.0 / 35.0 400	
	Voltage (V):				
Frequency (Hz):				50	
	Working condition class :			Class A	
	Acoustical environme	Hemi-anechoic room			
	Windshield type :			Sponge	
	Measured position a	14			
Measured quantity		L <sub>WA,indoors</sub> (dB(A))	L <sub>WA,outdoors</sub> (dB(A))	Remark	
Sound pressure level `L <sub>p(ST)</sub> ****			55		
Measurement distance d *			1.0m		
Sound power level L <sub>wA</sub> ****			70		

Setting of controls: according to user manual.

Duct connection:--

Rounding to: \*) 1 decimal places; \*\*) 2 decimal places; \*\*\*) 3 decimal places; \*\*\*\*) nearest integer

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 11 of 19





## **Technical Report**



## **Appendix I Test results**

Table 3b.	Sound power level	P			
Model	EF AD-P3-20K-S1				
	Product type :	Air to Water			
	Outdoor heat exchar	Outdoor heat exchanger, Air temperature DB/WB (°C):			
	Indoor heat exchanger, Water inlet/outlet temperature (°C):			47.0 / 55.0	
	Voltage (V):			400	
	Frequency (Hz):			50	
	Working condition class :			Class A	
	Acoustical environme	Hemi-anechoic room			
	Windshield type :			Sponge	
	Measured position a	14			
Measured quantity		L <sub>WA,indoors</sub> (dB(A))	L <sub>WA,outdoors</sub> (dB(A))	Remark	
Sound pressure level `L <sub>p(ST)</sub> ****			56		
Measurement distance d *			1.0m		
Sound power level L <sub>wA</sub> ****			72		

Setting of controls: according to user manual.

Duct connection:--

Rounding to: \*) 1 decimal places; \*\*) 2 decimal places; \*\*\*) 3 decimal places; \*\*\*\*) nearest integer

Doc No.: ITC-TTW0902.02E - Rev.13

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 12 of 19







Table 4.	Clause 4 of EN 14511-4:2022		
Model:	EF AD-P3-20K-S1		
TEST 1	STARTING TEST (§4.2.1.2 Table 3)		

Requirement: The "lower" starting operating conditions declared by the manufacturer for the heating modei.e. Tair= -25.05 °C, T out water = 12.15 °C, Flow rate 1.95 m³/h have been set and obtained. At those conditions, the machine was switched on.

Observation/ Evaluation: It started without any problem and worked for 30 minutes without showing any warning or alarm. During the test the machine operated in auto mode. No damage was recorded on the machine during and after the test.

Test Response: Pass

### TEST 2 OPERATING TEST (§4.2.1.2 Table 3)

Requirement: From the machine "lower" starting conditions - i.e. - the machine was brought to the lower operating conditions declared by the manufacturer for the heating mode- i.e. Tair= -25.22 °C, T out water = 75.15 °C, Flow rate 1.95 m³/h. Once these conditions were obtained, the machine was let operate for over 1 hour in auto mode.

Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.

Test Response: Pass

### TEST 3 SHUTTING OFF WATER FLOW (§ 4.5)

Requirement: The water flow rate was shuted off through manual and automatic valves of the test rig. The machine switched off and only the flow switch Protection appeared on the user interface of indoor unit.

Observation/ Evaluation: Perform error reset operation, once the water flow rate was restored, the machine restarted automatically and worked for 30 minutes normally. No damage was recorded on the machine during and after the test.

Test Response: Pass

#### TEST 4 SHUTTING OFF AIR FLOW (§ 4.5)

Requirement: The air flow rate was shutted off through a plastic sheet and a panel. The machine never turned off. It continued to operate with continuous frosting and defrosting cycles. After more than half an hour, the air flow rate was restored and the machine started to operate normally.

Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.

Test Response: Pass

#### TEST 5 COMPLETE POWER SUPPLY FAILURE (§ 4.6)

Requirement: The power supply was cut off for about 5 seconds.

Observation/ Evaluation: The unit restarted automatically within about 3 minutes after the power supply was reactivated.

Test Response: Pass

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 13 of 19



TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China







### **Appendix II Marking plate**

#### Nameplate Model: EF AD-P3-20K-S1 **EcoFlow PowerHeat Air-to-water Heat Pump** Model/Modell EF AD-P3-20K-S1 Made in China Power Supply/Spannungsversorgung 380-415V / 3N~ / 50Hz EC REP support.eu@ecoflow.com Heating Capacity<sub>1</sub> (kW)/Heizleistung<sub>1</sub> (kW) 6.70-20.36 EcoFlow Europe s.r.o. Doubravice 110, 533 53 Pardubice, Czech Republic Input Power<sub>1</sub> (kW)/Eingangsleistung<sub>1</sub> (kW) 1.12-4.62 support.eu@ecoflow.com Cooling Capacity<sub>2</sub> (kW)/Kühlleistung<sub>2</sub> (kW) 4.40-14.40 EcoFlow Innovation UK Limited Input Power<sub>2</sub> (kW)/Eingangsleistung<sub>2</sub> (kW) 0.95-4.69 41 Devonshire Street Ground Floor Office 1London United Kingdom Rated Input Power (kW)/Nenneingangsleistung (kW) 6.8 Manufacturer: EcoFlow Inc. RM 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road, Zhancheng Rated Running Current (A)/Nennbetriebsstrom (A) 11.6 Community, Fuhai Street, Bao'an District, Shenzhen City, Guangdong Rated Water Flow (m³/h)/Nenn-Wasserdurchflussrate (m³/h) 3.44 Province, P.R. China R290 / 1.65 Hotline Number/Hotline Nummer: -DE: 0800 0002566 Refrigerant Type/Filling Weight (kg) / Kältemitteltyp/Füllgewicht (kg) -AT: 0800 018 036 Net Weight (kg)/Nettgewicht (kg) 186 -UK: 0808 8126 006 1263 x 440 x 1375 Net Dimensions (L x W x H) (mm)/Abmessungen (L x B x M) (mm) Water Proof Class/IP-Schutzklasse IPX4 Protection Class against Electric Shock/Schutzklasse gegen elektrischen Schlag Max./Min. Refrigerant Pressure (MPa) / Max./Min. Kältemitteldruck (MPa) 3.0 / 0.9 Storage Refrigerant Pressure Range (Mpa)/Druckbereich des Kältemittels bei der Lagerung (Mpa) 3.5 . [Space Heating] Ambient Temp. (DB / WB):7°C / 6°C; 1. [Raumheizung] Umgebungstemp. (DB / WB):7°C / 6°C; Associate a Associate Associate Company of the Comp Water Temp. (Inlet / Outlet):30°C / 35°C Wassertemp. (Eintritt / Austritt):30°C / 35°C 2. [Space Cooling] Ambient Temp. (DB / WB):35°C / -; 2. [Raumkühlung] Umgebungstemp. (DB / WB):35°C / -; Water Temp.(Inlet / Outlet):12°C / 7°C Wassertemp. (Eintritt / Austritt):12°C / 7°C

Project No: 64.181.24.00376.01

Rev.: 00

Date: 2024-03-20 Page: 14 of 19







# Appendix III photo documentation

Details of:	Overall view		
View:  General Front Rear Right Left Top Bottom	■COFLOW		

Project No: 64.181.24.00376.01

Rev.: 00

Date: 2024-03-20 Page: 15 of 19 www.tuvsud.com



 $\mbox{T\"{U}V}$   $\mbox{S\"{U}D}$  Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



# Appendix III photo documentation

Details of:	Fan Motor
View:  General  Front Rear Right Left Top Bottom	BRUSHLESS DC MOTOR (EM ATRICAMAN)  DC3107  150W 950x/ain  Manufacturing Cu, its Mark &

Details of:	Main Control Board
View:  General  Front Rear Right Left Top Bottom	

Project No: 64.181.24.00376.01

Rev.: 00

Date: 2024-03-20 Page: 16 of 19 www.tuvsud.com

TÜV®

 $\mbox{T\"{U}V}$   $\mbox{S\"{U}D}$  Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



# Appendix III photo documentation

Details of:	Water Pump
View:  General  Front  Rear  Right  Left  Top  Bottom	230V AC   50Hz.   P1(VV)   140   6.6     Class H   TF 95   (/A)   1.09   0.08     P44   EEIS 02.1-Part 3   MP8   1.0     GPA25-11H

Project No: 64.181.24.00376.01

Rev.: 00

Date: 2024-03-20 Page: 17 of 19 www.tuvsud.com







## **Appendix IV Construction data form**

Model: <u>EF AD-P3-20K-S1</u>				
Part		Technical data		
1. Compressor				
	Manufacture:	Shanghai Highly Electrical Appliances Co .,Ltd		
	Type:	WHP32900VSKTQ9JK		
	Rated capacity:	4260W		
	Serial-number:	W82N1E02NMNJ		
	Specification:	DC221V; R290		
2. Condenser				
	Manufacture:	Guangzhou Panyu Xinsuneng Board Heat Exchanger Co., Ltd.		
	Type:	MTB090HP-47-Q		
	Heat exchanger:	Plate heat exchanger		
	Dimension(mm):	541.8mm×126.6mm×94mm		
3. Evaporator				
	Manufacture:	Guangzhou Aotai Refrigeration Equipment Co., Ltd.		
	Type:	NE-F200HCR4TINVM-SD+		
	Heat exchanger:	Fin heat exchanger		
	Dimension(mm):	25mm×21.65mm×1.8mm×2		
4. Fan motor				
	Manufacture:	Zhuhai Kaibang Motor Manufacture Co.,Ltd		
	Type:	ZWS150-H68		
	Fan type:	4 blade		
	Specification:	DC310V; 150W		
5. Main control board				
	Manufacture:	Guangzhou Punp Electronic Co., Ltd.		
	Type:	K.LK050085A.01		
	Specification:	220-240V~/50Hz		
6. Water pump				
	Manufacture:	Hefei Xinhu Canned Motor Pump Co.,Ltd.		
	Type:	GPA25-11H		
	Specification:	230VAC; 50Hz; 140W		

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 18 of 19 www.tuvsud.com





## **Appendix V Equipment List**

No.	Туре	Manufacture	Model	Equipment ID	Calibration Due Date
1	Heat pump energy efficiency testing system	PINXIN	10HP	2017J00001	2023-11-24
2	Electromagnetic flowmeter	KROHNE	OPTIFLUX4100C	H17221264	2023-12-21
3	Anechoic rooms (hemi-anechoic rooms)	Guangzhou Kinte	-	NC-036-2	2023-10-07
4	AC source Supply	YANGHONG	YF-3600	VGDS-0637	2023-11-07
5	6 channel data logger	_	PXI-1033	VGDY-0257	2024-05-20
6	PULSE system	B & K	3660C	VGDY-0184	2024-04-12
7	Calibrator	B & K	4231	HJ-000095	2024-06-30
8	Long steel tape	_	5m	HJ-000150	2024-01-01
9	Temperature measurement system	_	_	NC-036-1	2024-06-07
10	Atmospheric pressure meter	_	_	HJ-000165	2023-11-22
11	Constant temperature water system	B & K	_	VGDS-0448	2024-04-18
12	Windscreen	B & K	WS002-5	_	_

-- End of Report --

Project No: 64.181.24.00376.01

Rev.: 00 Date: 2024-03-20 Page: 19 of 19  $\underline{www.tuvsud.com}$ 

